

DERRY FIRE DEPARTMENT



JAMES K. RICHARDSON
FIRE CHIEF

14 MANNING STREET
DERRY, NH 03038
603-432-6121
DERRYNH.ORG

SHAWN M. HAGGART
ASSISTANT CHIEF



Excellence through Professionalism, Integrity, and Compassion

Attention All Installation Contractors:

The Town of Derry Fire Department uses an online permitting program (Permitize). This program is available to you remotely. Alternatively, we have a computer in the Derry Municipal Center's main lobby for use. This program is used for installation permits that you were previously required to visit the office to obtain. All users will be required to open an account and payments will be made through the online program. The following payments will be accepted: Visa, Master Card, American Express, Discover and direct withdrawal from your checking account (EFT Check). Cash or Check will be the only form of payment accepted in the office.

You can reach Permitize by following this link:

https://fctpermit.com/sites/Derry/derfire/user_login.asp

Please visit our website for a list of the current adopted Town & State of NH Fire Codes:

<https://www.derrynh.org/fire-department/pages/fire-prevention-inspection>

List of common Re-Inspection Issues:

1. Must have working Smoke & Carbon Monoxide Detection Present for all Fuel Burning Equipment installations
2. The building address must be affixed to the building with 4.5" stroke numbers.
3. Contrasting Primer is required on all PVC exhaust vent piping.
4. Installations must follow manufacturer installation instructions and the manuals must be available for reference.
5. A Tempering Valve is required for all Hot Water Tanks with a minimum temperature setting point of 140° F.
6. All Type B Vent piping must be tight fitting and Foil tape shall not be used to perform a seal.
7. Gas piping – Failed pressure test due to bad/defective gauges.
8. Gas CSST type piping that is not properly bonded
9. Improper Make-up air