

Will we be required to provide air balancing for the new RTU's? *Air balancing will not be required for the new RTU. It will be performed outside of this contract.*

Control wiring and terminations are by others including duct smoke detectors and not the responsibility of the RTU replacement contractor? *Control wiring and duct smoke detectors will be completed by others outside of this contract.*

New gas regulators for each RTU? Yes or no? *New gas regulators will need to be supplied and installed as part of this contract.*

Permit fees waived or should we include fees? *Permits must be applied for but all permit fees will be waived.*