

Answers to questions on RTU project for the Veterans Memorial Building

Will project require a payment and performance bond? *Under State of New Hampshire RSA 447:16 only projects exceeding \$125,000.00 require a Payment and Performance Bond.*

What is the existing circuit breaker size for the existing RTU? *The existing circuit breaker is 125 amp.*