

April 16, 2018

### #1 - Response to Vendor Questions

1. Do you want to make removing the old camera coax wires part of the project? I can make it an alternate price if necessary.

As part of formulating the bid price, the bidder should assume that all abandoned coaxial wire associated with the CCTV upgrade project will be removed by the vendor. The vendor will make arrangements to properly dispose of the coaxial wire