

Town of Derry, NH

BID Questions – Don Ball Landing Strip Football Field Project

Questions & Answers:

- 1) Please explain in more detail when the specifications in the RFP state “spread product/sports sand to create a crown? **Loam will be needed to create a crown of 12-18 inches to help with drainage. It is desirable for the topsoil to consist of a sandy loam soil containing less than 30 percent silt and less than 10 percent clay.**
- 2) Is fertilizer and lime necessary per the specifications? **No. The bid – rather – should include pricing for the seeding of this ½ field (Landing Strip, Football Field) area with a high quality landscaper seed mix.**