

B23-105: Derry Transfer Station – Sprinkler System Improvements

Q & A

Scope of work on the plan itself states flushing system and hydrostatic test. Is this correct?

SFC will not require hydrostatic testing and flushing upon completion of the sprinkler modifications.

What is the height of the Transfer Station?

It is 36.5 feet floor to roof on the front and 26.5 feet high on the back wall – where most of the sprinkler work will be conducted.