

Town of Derry, New Hampshire

Trenchless Sewer Pipeline Rehabilitation B24-106 Closing Date 4/19/24

Name	Company	Address
Nate Holmes	Insituform Technologies	269 Neck Rd / Benton, ME 04901
Michael Paradis	Vortex Services	521 Federal Road /Livermore, ME 04253
Adam Stearns	Green Mountain Pipeline Services	768 South Main/ Bethel, VT 05032

Questions Answered

Q- "8" x 6.0mm or equivalent" Will 8" x 4.75mm Be considered as Equivalent?

A- Yes proposals 8" x 4.75mm (wall thickness) will be considered.
