## Please use water wisely!

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The US Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Why are contaminants in my water? Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

**Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Water Efficiency Tip	Estimated Savings
Adjust sprinklers to prevent overspray and runoff	15–25 gallons/day
Repair leaks and broken sprinkler nozzles	10 gallons/minute/leak
Add 2" to 3" of mulch around trees & plants to reduce evaporation	20-30 gallons/day/1,000 sq. ft.
Install drip irrigation system for trees, shrubs, and flowers to get water to the plant's roots more efficiently	20–25 gallons/day
Upgrade to a "smart irrigation controller" that automatically adjusts watering times based on weather conditions	40 gallons/day
Replace your lawn and upgrade to WaterSmart landscape	33-60 gallons/day/1,000 sq. ft.
Use a broom instead of a hose to clean driveways and sidewalks	8–18 gallons/minute
Adjust your pressure reducer (if you have one) to keep pressure between 40 and 60 p.s.i.	Varies
While washing your car, use a self-closing nozzle for your hose	8–18 gallons/minute
Repair any leaks around pool and spa pumps	20 gallons/day/leak
Repair leaking hose bibs	15–20 gal./day/leak
Install covers on pool and spas to reduce evaporation	30 gallons per day
Install pressure reducer if your pressure is greater than 80 p.s.i.	Varies

#### **Source Water Assessment Summary:**

Source	Summary of Susceptibility Factors			
		Low	Med	High
Source Name and Description	BRW 1	9	0	3
Source Name and Description	BRW 2	9	0	3
Source Name and Description	BRW 3	8	2	2

Souce Water Assessments are prepared by the NH Department of Environmental Services and are conducted to identify potential contamination sources within the protection area of public water supply wells. This allows communities to develop and implement source water protection programs. The complete assessment report for the Rand Shepard Hill system is available at the Derry Department of Public Works, For more information you may contact the DPW at 603-432-6144 or visit the NHDES website at

http://des.nh.gov/organization/divisions/water/dwgb/dwspp/reports/documents/derry.pdf

Note: This information is over 12 years old and includes information that was current at the time the report was completed. Therefore, some of the ratings might be different if updated to reflect current information. At the present time. DES has no plans to update this data.

**Do I need to take special precautions?** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

How can I get involved? The Town of Derry invites its customers to become more involved with the Town's water quality efforts. The Derry Town Council, who act as the Water Commission, meet periodically to discuss issues that concern our customers. Council meetings are usually held on the first and third Tuesdays of each month at the Derry Municipal Center at 14 Manning Street. For more information you can call the Municipal Center or visit our website www.derrynh.org.

## Town of Derry, New Hampshire

Rand-Shepard Hill Community

Water System

**ANNUAL** 

# CONSUMER CONFIDENCE REPORT

# Drinking water testing report

For testing done in 2019

PWS ID 0612230



Department of Public Works 14 Manning Street

Derry, NH 03038

Tel: 603-432-6147

### To Our Customers at Rand-Shepard Hill,

The Town of Derry continues its ongoing mission of providing safe and reliable drinking water to Derry's residents, institutions and businesses and complying with Federal and State Regulations. Aging infrastructure and watershed maintenance present challenges to drinking water safety. Education, diligence and continuous maintenance and improvements are needed to maintain the quality of life we desire for today and for the future. Each year the Town budgets for the replacements of older undersized water pipelines, and valves throughout our water system as well as repairs and upgrades to our pump stations and water supply wells.

These investments along with on-going operation and maintenance costs are supported by our water rates and fees. When considering the high value we place on water, it is truly a bargain to have water service that protects public health, and provides us with the high-quality of life we enjoy.

What is a Consumer Confidence Report? The Consumer Confidence Report (CCR) details the quality of your drinking water, where it comes from, and where you can get more information. This annual report documents all detected primary drinking water parameters, and compares them to their respective standards known as Maximum Contaminant Levels (MCLs).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

#### What is the source of my drinking water?

The Derry Rand-Shepherd Hill Community Water System is serviced by three groundwater supply bedrock wells located off Londonderry Road, a storage tank, a water booster station, and 5,800 feet of ductile iron water lines. Chlorine is injected prior to distribution in order to maintain adequate disinfection. The system provides drinking water to 63 single family residential homes on Faith Dr., Twilight Path and Heather Lane. Please remember to restrict outdoor watering activities to the early morning or evening hours on your even or odd scheduled day.

#### **Please Help Protect Drinking Water**

You are probably already aware that certain activities on your property can affect the quality of groundwater. Most people who have septic systems are aware that their septic system discharges to the ground and thus to groundwater. Similarly, any gasoline, motor oil, paint, garden chemicals, lawn chemicals, or other household chemicals that are spilled, sprayed, spread, or dumped onto the ground can make their way into groundwater. Because your property is within the source water protection area of the Rand-Shepard Hill wells, activities on your property that affect groundwater can also affect the drinking water supply. We ask that residents be diligent in this regard and properly dispose of any household chemicals at the Derry-Londonderry biannual Household Hazardous Waste Collections days held in May and October each year. Look for information on our website at www.derrynh.org.

## Town of Derry, NH Rand-Shepard Hill Community Water System Sampling Results for 2019

The Table below lists the contaminants detected in Derry's Rand-Shepard Hill Community Water System in 2019. In addition to those detected, the Town tests your drinking water for over 100 additional contaminants such as pesticides, herbicides, radionuclides, MTBE etc. using both Town resources and local laboratories.

How to read this table: This table shows the results of our water quality analyses. Every regulated contaminant that we detected in your water, even in the minutest traces, is listed here. The table contains the names of each contaminant, the highest level allowed by State and EPA regulations (MCL), the ideal goals for public health (MCLG), the amount detected, and the most common sources of the contaminant. Footnotes explaining our findings and a key to the units of measure are also included in this table. Definitions of MCL and MCLG are important.

	DETECTED WATER QUALITY RESULTS								
CONTAMINANT (Units)	YEAR SAMPLED <sup>1</sup>	HIGHEST LEVEL DETECTED	MCL	CL MCLG VIOLATION YES/NO		LIKELY SOURCE OF CONTAMINANT			
Barium (ppm)	2019	0.112	2	N/A	NO	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits			
Chlorine (ppm)	2019	MONTHLY AVERAGE: 0.34 RANGE of DETECTED VALUES = 0.07 to 0.34	MRDL = 4	MRDLG = 4	NO	Water additive used for disinfection; to control microbes			
Copper (ppm)	2018	90 <sup>th</sup> percentile = 0.324 	AL = 1.3	AL = 1.3	NO	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives			
Lead (ppb)	2018	90 <sup>th</sup> percentile = 1 # of samples exceeding AL = 0	AL=15	0	NO	Corrosion of household plumbing systems, erosion of natural deposits			
Nitrate as Nitrogen (ppm)	2019	0.46	10	10	No Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of n deposits				
RADIOLOGICAL CONTAIN	MINANTS								
Compliance Gross Alpha (pCi/L)	2016	5.3 +/- 1.4	15	0	NO	Erosion of natural deposits			
Uranium (mass –ug/l)	2016	2.8	30	0 NO		Erosion of natural deposits			
Combined Radium 226 & 228 (pCi/L)	2016	1 +/- 0.4	5	0 NO		Erosion of natural deposits			
DISINFECTION BYPRODUCTS				_	_				
Total Trihalomethanes (TTHM) ppb (Bromodichloro-methane Bromoform Dibromomethane Chloroform)	2019	RAA = 4.2	RAA = 80	N/A	NO	By-product of drinking water chlorination			
Haloacetic Acids (HAA) (ppb)	2019	RAA = 1.4	RAA = 60	NA NO		By-product of drinking water disinfection			
ADDITIONAL TESTING		RANGE OF DETECTED VALUES		AVERAGE VALUE		WHY DO WE TEST FOR THESE CONTAMINANTS?			
Sodium (ppm)	2019	23		23					
Manganese (ppm)	2019	0.120		0.120					
Magnesium (ppm)	2014	3.65		3.65		The Derry Rand-Shepard Hill Community Water System is required by the Safe			
Zinc (ppm)	2019	0.0338	0.0338			Drinking water Act (SDWA) to sample its water system for inorganic compound (IOC's). Derry will sample for these contaminants more frequently as they are in			
Chloride (ppm)	2019	69		69		some cases of common interest to consumers.			
Sulfate (ppm)	2019	32		32					
Hardness (mg CaCO <sub>3</sub> /l)	2014	141		141					

D	El	FII	N	IT	IC	1	V.	S	

**Action Level** or **AL:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level** or **MCL**: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** or **MCLG**: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level** or **MRDL:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal** or **MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Treatment Technique** or **TT**: A required process intended to reduce the level of a contaminant in drinking water.

#### **Abbreviations**

BDL: Below Detection Limit
NA: Not Applicable
pCi/L: picoCurie per Liter
ppb: parts per billion
RAA: Running Annual Average

mg/L: milligrams per Liter
ND: Not Detectable at testing limits
ug/L: micrograms per Liter
ppm: parts per million

#### **CONTAMINANTS**

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water system is responsible for high quality drinking water, but cannot control the variety of materials used in your plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing cold water from your tap for at least 30 seconds before using water for drinking or cooking. Do not use hot water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <a href="http://water.epa.gov/drink/info/lead/index.cfm">http://water.epa.gov/drink/info/lead/index.cfm</a>

UNREGULATED SUBSTANCES		RANGE DETECTED	AVERAGE VALUE	HEALTH ADVISORY	LIKELY SOURCE OF CONTAMINANT
Perfluorooctanic Acid (PFOA) (ppb)	2019	0.00734	0.00734	0.070	Industrial pollutant
Chromium (ppm)	2019	0.0031	0.0031	0.1	Naturally Occurring; Industrial Pollutant

The State of NH and EPA allow for water systems to monitor for contaminants noted less than once per year because the concentrations for these contaminants do not change frequently.