

February 9, 2018  
B18-127

Town of Derry, NH Department of Public Works  
14 Manning Street  
Derry, NH 03038

To: Prospective Bidders:

SPECIFICATIONS AND CONTRACT DOCUMENTS FOR TO FABRICATE, SUPPLY and CONSTRUCT A

**PRE-ENGINEERED STEEL GARAGE BUILDING**

FOR THE DERRY, NH DEPARTMENT OF PUBLIC WORKS WASTEWATER DIVISION (B18-127  
January 25, 2018) are herein AMENDED on February 9, 2018 as follows:

The Bay Spacing for both end walls and side walls shall be 20 feet.

The 3 framed garage door openings shall be located on the Left End Wall (LEW).

Manufacturing and delivery Time is extended to 120 days. Upon selection of the successful bid, the contractor will provide to the Town the requisite design drawings and specifications which will allow the Town to complete the site preparation, footings and slab.

For any further clarifications or questions, please contact:

Thomas Carrier

Deputy DPW Director

14 Manning Street, Derry, NH 03038

Tel. 603-432-6147; Fax; 603-432-6130

Email: [tomcarrier@derrynh.org](mailto:tomcarrier@derrynh.org)

Bid Opening Date/Time: March 6, 2018 at 2:00 P.M.